

**To:** Richard Barnett [REDACTED]  
**From:** [REDACTED]  
**Sent:** Mon 8/19/2013 8:38:52 PM  
**Subject:** Re: JE coming back this Thurs. Aug. 22nd

oh boy! ok, thanks...  
you are keeping busy!

On Aug 19, 2013, at 4:35 PM, Richard Barnett wrote:

Hi [REDACTED] the Chiller & Cooling Tower installation is almost complete but we have one issue that may impact the system from operating at 100% cooling capacity by Thursday Aug.22nd . We found both Cooling Tower motors from the manufacturer defective during the commissioning test phase today . Both motors are two speed ,the fan motors both run in low speed but not in high speed . The high speed cycle is needed when the outside temperature rises, and due to the expected hot weather the high speed is needed . I will find out by tomorrow when the new replacement motors will be installed. I am currently running 80% of the house ac fan unit equipment with both cooling towers in low speed and maintaining proper set points. I want Mr. Epstein to know if the new motors are not installed by Wednesday, I would have to load shed to keep his master bedroom cool at night. I will have a better idea of the motor replacement status by tomorrow. Richard

> From: [REDACTED]  
> Subject: JE coming back this Thurs. Aug. 22nd  
> Date: Mon, 19 Aug 2013 15:28:12 -0400  
> To: [REDACTED]  
>  
> Hi Rich..hope all is well! Jeffrey requested I check in with you and make sure the house will be ready for his arrival this Thursday Aug. 22nd...He is due to land around 6-6:30pm...please let me know! thanks, [REDACTED]